
Simulation and implementation of Perturb and Observe Maximum Power Point Tracking System (MPPT) With Parallel Connection for PV Stand-Alone Application

Prashant Kadi

Asst Prof

B.L.D.E.A.'S CET

Vijayapurkarnataka

Abstract—This paper presents the analysis, design, and implementation of a parallel connected maximum power point tracking (MPPT) system for stand-alone photovoltaic power generation. Maximum power point tracking (MPPT) plays an important role in photovoltaic systems because it maximizes the power output from a PV system for a given set of conditions, and therefore maximizes the array efficiency and minimizes the overall system cost. Since the maximum power point (MPP) varies, based on the irradiation and cell temperature, appropriate algorithms must be utilized to track the (MPP) and maintain the operation of the system in it. Matlab/Simulink is used to establish a model of photovoltaic system with (MPPT) function. The parallel connection of the MPPT system reduces the negative influence of power converter losses in the overall efficiency because only a part of the generated power is processed by the MPPT system. Furthermore, all control algorithms used in the classical series-connected MPPT can be applied to the parallel system. A simple bidirectional dc–dc power converter is proposed for the MPPT implementation and presents the functions of battery charger and step-up converter. The operation characteristics of the proposed circuit are analysed with the implementation of a prototype in a practical application.

Keywords—DC–DC power conversion, photovoltaic (PV) power systems, solar energy.

I. INTRODUCTION

THE CONTINUOUS growth of the global energy demand associated with society's increasing awareness of environmental impacts from the widespread utilization of fossil fuels has led to the exploration of renewable energy sources, such as photovoltaic (PV) technology. Therefore, several studies are being developed in order to minimize these drawbacks. In order to extract the maximum

power of the PV array, the classical implementation of the maximum power point tracking (MPPT) in stand-alone systems is generally accomplished by the series connection of a dc–dc converter between the PV array and the load or the energy storage element. Considering that in the series connection, the dc–dc converter always processes all power generated, the total efficiency of the PV system greatly depends on the efficiency of this series dc–dc converter. As an alternative to this configuration, this paper presents an MPPT system based on the parallel connection of a dc–dc converter. With this configuration, only part of the energy generated is processed by the dc–dc converter, making it possible to obtain an increase in the total efficiency of the PV system as compared with the series configuration. Methodology and experimental results of a laboratory prototype of the parallel MPPT system are presented in this paper.

II. MPPT IN STAND-ALONE PV SYSTEMS

A. Solar Cell Output Characteristic

The maximum power of the PV module changes with climatic

conditions, and there is only one value for the current (I_{mpp}) and the voltage (V_{mpp}), which defines the maximum power point (MPP), as shown in Fig. 1. The PV current changes with the solar irradiation level, whereas the PV output Voltage changes with the temperature of the PV module. Therefore, an important challenge in a PV system is to ensure the maximum energy generation from the PV array with a dynamic variation of its output characteristic and with the connection of a variable

load. A solution for this problem is the insertion of a power converter between the PV array and load, which could dynamically change the impedance of the circuit by using a control algorithm. Thus, MPP operation can be obtained under any operational condition.




Fig. 1 Output characteristic of a PV module

B. Simulink Model of Solar PV Module

Solar cell is basically a p-n junction fabricated in a thin wafer or layer of semiconductor. The electromagnetic radiation of solar energy can be directly converted to electricity through photovoltaic effect. Being exposed to the sunlight, photons with energy greater than the band-gap energy of the semiconductor are absorbed and create some electron-hole pairs proportional to the incident irradiation. Under the influence of the internal electric fields of the p-n junction, these carriers are swept apart and create a photocurrent which is directly proportional to solar insolation. PV system naturally exhibits a nonlinear I-V and P-V characteristics which vary with the radiant intensity and cell temperature. Fig. 2 shows the equivalent circuit models of cell and Fig.3 shows the simulation circuit in mat lab.




Fig.2 Equivalent circuit model of pv cell




Fig.3 Simulation circuit of the PV module

Since a typical PV cell produces less than 2W at 0.5V approximately, the cells must be connected in series configuration on a module to produce enough high power. A PV array is a group of several PV modules which are electrically connected in series and parallel circuits to generate the required current and voltage. The equivalent circuit for the solar module arranged in NP parallel and NS series is shown in Fig. 2. The terminal equation for the current and voltage of the array becomes as follows.

$$I = N_p I_{ph} - N_p I_s \left[\exp\left(\frac{q(V/N_s + I R_s/N_p)}{K T C A}\right) - 1 \right] - \frac{N_p V/N_s + I R_s}{R_{sh}} \dots \dots \dots 1$$

where, I_{PH} is a light-generated current or photocurrent, I the cell saturation of dark current, q electron charge, k is a Boltzmann's constant, T_C is the cell's working temperature, A is an ideal factor, R_{SH} is a shunt resistance, and R_S is a series resistance.

The photocurrent mainly depends on the solar insolation and cell's working temperature, which is described as

$$I_{ph} = [I_{sc} + K_1(T_c - T_{ref})] \dots \dots \dots 2$$

where ISC is the cell's short-circuit current at a 25 kW/m², KI is the cell's short-circuit current temperature coefficient, T_{Ref} is the cell's reference temperature, and the solar insolation in kW/m².

C. Parallel Connection of the MPPT

Fig. 4 shows an alternative proposal to implement standalone PV power generation based on a parallel MPPT system. The parallel connection of the MPPT circuit was introduced in Fig.4, and the main advantage of this configuration is that the dc-dc converter processes only a part of the generated power, allowing for higher efficiency as compared with the series configuration. In line with this concept, an integrated power circuit is proposed in this paper with the following multiple functions: battery charge, battery regulator, and step up converter. The best operation condition occurs when the load current value is equal to the PV module MPP current value (I_{mpp}), where the dc-dc converter does not process power.

This may represent a significant increase in the overall efficiency and reliability of the system, which is besides enabling a reduction in the cost of the electronic system utilized. On the other hand, the series connection of a higher number of PV modules would present a significant reduction in the energy generated and could make it difficult to obtain the MPP in cases of shading/defect of one or more PV modules.

The output characteristic of two PV modules under two different sunlight conditions is shown in Fig. 5. The black curve represents the output characteristic of the module operating with total solar irradiation, and the gray curve represents the output characteristic of a shaded module operating with partial solar irradiation. Fig.6 shows the equivalent output characteristic of PV modules connected in series, where one module operates with partial solar irradiation.




Fig. 4 MPPT System with parallel connection for PV




Fig. 5 Output curve of (gray line) shaded and (black line) unshaded PV modules.




Fig. 5 Output curve of (gray line) shaded and (black line) unshaded PV modules.

III. PROPOSED MPPT CONTROLLER

A. Power Circuit Operation

In order to verify the operation characteristics of the proposed parallel MPPT system shown in Fig. 7, only a dc load connected in parallel with the PV module was considered. It was composed of a battery bank storage energy, (C) a capacitor, (L) an inductor, and a power semiconductor leg (S1-D1 and S2-D2). The bidirectional converter operates as a buck converter in the battery charge mode and as a boost converter when the battery must supply the load (RL) or when the load energy demand is higher than the energy generated.

The converter duty cycle is generated by the same control algorithms that are used in the series-connected MPPT.

The operation analysis of the proposed converter is presented for use with hard-switching pulse width modulation. However, it must be highlighted that the power circuit efficiency can be improved by using soft-switching techniques.

1) Buck Operation Mode: Fig. 8 shows the two topological stages that occur during the buck operation mode. The battery bank voltage must be lower than the PV module voltage for correct operation. When the energy generated is enough to supply the load, the exceeding energy is used to charge the battery. When the power switch S1 is turned on, the inductor L stores energy, and the energy flows from the PV module to the battery bank. When the power switch S1 is turned off, the diode D2 conducts, and the energy stored in the inductor L is transferred to the battery. The switches' command signals are complementary, and therefore, the switch S2 is turned on during the conduction of the diode D2.

2) Boost Operation Mode: If the energy generated at the MPP is not enough to supply the load, the power system operates as a boost converter, transferring energy from the battery to the load. In this case, while the switch S2 is turned on, the inductor L stores energy from the battery, as shown in Fig. 9. When the switch S2 is turned off, the energy stored in the inductor is transferred to the load. Fig. 10 shows the command signal of the power switches S1 (VCS1) and S2 (VCS2) and the inductor current waveform (i_L) in the buck and boost operations.

The greatest advantage of the proposed parallel MPPT system with a bidirectional power circuit, which is as shown in Fig. 7, is the integration of multiple functions in a single cost-effective converter, which combines simplicity, reliability, and low cost. The multiple functions of the proposed system areas follows: battery bank charger, which is when the energy generated by the PV array is higher than the load consumption; MPPT controller, which is in order to extract the maximum energy from the PV array; and step-up dc-dc converter, which is when the energy of the PV array is not enough to supply the load. The control algorithm ensures the operation of the PV module at the MPP, implementing the MPPT function.




Fig. 7 MPPT System with bidirectional dc-dc converter.




Fig. 8. Buck operation mode. (a) S1 turned on. (b) S1 turned off.




Fig.9 Boost Operation mode. (a) S2 turned on. (b) S2 turned off




Fig. 10 Bidirectional Operation of the inductor current.

B. Control Algorithms

1) Perturb And Observe MPPT Algorithm:

The PV voltage and current are monitored, and the PV power can be controlled as in the series connected system. There are many studies that analyse the energy efficiency of different MPPT algorithms, the transition between the different operations modes must occur without discontinuity of the load in the parallel-connected MPPT system. The convergence time of the MPPT algorithm is, normally, not important for the series connected

system because the climatic transitions occur with a high constant time and because the load is connected to the battery bank. However, the utilization of a fast convergence MPPT algorithm is important for the parallel system in order to minimize the transient in the output voltage with the load variation. As the analysis of the MPPT algorithm was not the focus of this paper, the perturbation and observation method was utilized, and the control algorithm is shown in Fig. 11. The algorithm reads the value of current and voltage from the solar PV module. Power is calculated from the measured voltage and current. The value of voltage and power at k th instant are stored. Then next values at $(k+1)$ th instant are measured again and power is calculated from the measured values. The power and voltage at $(k+1)$ th instant are subtracted with the values from k th instant. If we observe the power voltage curve of the solar pv module we see that in the right hand side curve where the voltage is almost constant the slope of power voltage is negative ($dP/dV < 0$) whereas in the left hand side the slope is positive ($dP/dV > 0$). The right side curve is for the lower duty cycle (nearer to zero) whereas the left side curve is for the higher duty cycle (nearer to unity). Depending on the sign of dP ($P(k+1) - P(k)$) and dV ($V(k+1) - V(k)$) after subtraction the algorithm decides whether to increase the duty cycle or to reduce it.




Fig.11 Perturb Observe MPPT Algorithm




Fig.12 Simulation Circuit Of Perturb and Observe MPPT Algorithm.

2) Battery Charge Control: While the PV module generates energy, the MPPT algorithm is active and maintains the PV module operating with maximum power. If the PV current is higher than the load current, the battery bank is charged with the difference between these currents. The PV module presents a current source output characteristic at the maximum

Current value as shown in Fig.1. Therefore, if the maximum PV current is considered in the design of the battery bank, a current control loop is not necessary to limit the maximum battery charge current. The highest battery charge current occurs when the system operates with maximum solar irradiation and without load. When PV-generated energy is lower than the load demand, the necessary additional energy is supplied by the battery bank. Thus, the charge or discharge battery current is controlled by the MPPT algorithm. During the operation of the MPPT algorithm, the battery state of charge is verified, and when the state of charge reaches its lowest level, the battery discharge function is disabled, and the system is turned off. In addition, when the battery state of charge reaches its highest limit level, the MPPT algorithm is disabled, and the output voltage control loop is enabled (operation mode 5). In this case, the reference voltage adopted for the constant voltage control loop must define an output voltage that is close to the PV MPP voltage but higher in order to allow for the battery discharge. After a small partial battery discharge, the MPPT algorithm returns to operation and a cyclic transition between the MPPT and voltage regulation algorithm occurs while the battery is fully charged and the energy generated is higher than the load energy demand. The control

algorithm developed for the parallel MPPT operates only with the battery bank connected to the system.

3) Voltage Control Loop: The voltage control loop is also activated when the energy from the PV module is very low or

null. In this case, the MPPT algorithm is disabled, the dc–dc power circuit operates as a boost converter, and the battery bank supplies the load with a constant voltage. In this situation, the reference voltage defined in the control algorithm is compared with the output voltage, and the error signal is applied to the digital voltage compensator. The control action defines the converter duty cycle in order to regulate the output voltage. The voltage reference considered is equal to 15 V, which is the intermediate value of the MPP voltage of the PV module utilized in the practical implementation. As occurs with the MPPT algorithm during the voltage control loop operation, the battery state of charge is verified, and the system is turned off when the battery reaches its lowest level.

IV. EXPERIMENTAL RESULTS

The operation of the proposed system was tested with the implementation of a laboratory prototype, which is shown. The PV module utilized in the practical test was the Kyocera Solar KC40T with maximum power equal to 50 W.

A. MPPT Operation

The practical implementation of the control algorithms was accomplished with the microcontroller PIC16F1877A. The data acquisition was obtained through serial transmission from the microcontroller to a computer. The main control information, such as voltage, current, power, and converter duty cycle, is stored during MPPT operation. Considering a load resistance that is equal to 12 Ω . Fig. 13 shows the PV module power and current.

A. Fig. 13 shows the PV module output current and voltage curve, as well as two load lines. The lower line represents the connection of the load resistance directly to the PV module without the MPPT circuit. Thus, the 25% gain in power obtained with the MPPT was used to store energy in the battery. The complete hardware of the project is shown in fig.14




Fig. 13 Output Current and voltage of the PV module.



Fig.14 Complete Hardware of the Project

V. CONCLUSION

In this paper a standalone PV system has been simulated by Mat lab/Simulink. Perturb and observe algorithm has been used for maximum power point tracking. Simulation results show that the system operates in the maximum power point for the different irradiances values. An MPPT circuit with parallel connection is presented in this paper. The parallel connection of the MPPT system reduces the negative influence of power converter losses in the overall efficiency during PV power generation. The control algorithm ensures operation at the MPP as in the classical system; however, only a part of the power generated is processed by the dc–dc converter. The power converter implemented is multifunctional, operating as an MPPT circuit, battery charge, battery regulator, and step-up converter. A stand-alone generation system, with a reduced number of energy-processing stages, is proposed, allowing for the implementation of a high-efficiency PV system. The main operational aspects of the parallel MPPT were verified with the implementation of a prototype. The transitions of the different operational modes were tested and occurred without any discontinuity of the system's operation.

REFERENCES

- [1] E. V. Solodovnik, S. Liu, and R. A. Dougal, "Power controller design for maximum power tracking in solar installations," *IEEE Trans. Power Electron.*, vol. 19, no. 5, pp. 1295–1304, Sep. 2004.
- [2] M. A. S. Masoum, S. M. M. Badejani, and E. F. Fuchs, "Microprocessor controlled new class of optimal battery chargers for photovoltaic applications," *IEEE Trans. Energy Convers.*, vol. 19, no. 3, pp. 599–606, Sep. 2004
- [3] W. Xiao, N. Ozog, and W. G. Dunford, "Topology study of photovoltaic interface for maximum power point tracking," *IEEE Trans. Ind. Electron.*, vol. 54, no. 3, pp. 1696–1704, Jun. 2007.
- [4] W. Xiao, W. G. Dunford, P. R. Palmer, and A. Capel, "Application of centered differentiation and steepest descent to maximum power point tracking," *IEEE Trans. Ind. Electron.*, vol. 54, no. 5, pp. 2539–2549, Oct. 2007
- [5] N. Femia, G. Petron, G. Spagnuolo, and M. Vitelli, "Optimization of perturb and observe maximum power point tracking method," *IEEE Trans. Power Electron.*, vol. 20, no. 4, pp. 963–973, Jul. 2005.
- [6] M. G. Simões and N. N. Franceschetti, "Fuzzy optimisation based control of a solar array system," *Proc. Inst. Electr. Eng.—Electric Power Applications*, vol. 146, no. 5, pp. 552–558, Sep. 1999.
- [7] J. A. Abu-Qahouq, H. Mao, H. J. Al-Atrash, and I. Batarseh, "Maximum efficiency point tracking (MEPT) method and digital dead time control implementation," *IEEE Trans. Power Electron.*, vol. 21, no. 5, pp. 1273–1281, Sep. 2006
- [8]

